

DATE: January 12, 2026

DEPARTMENT OF GENERAL SERVICES
BUREAU OF CAPITAL PROJECT DESIGN MANAGEMENT
1800 HERR STREET
HARRISBURG, PENNSYLVANIA

ADDENDUM NO. 12

on

PROJECT NO. DGS C-0948-0090 PHASE 003

**PROJECT TITLE - Capitol Complex Central Plant - Building Renovations, Chiller System
Replacement and Electrical System Upgrades**

PROFESSIONAL:

H.F. Lenz Co.

1407 Scalp Avenue

Johnstown, Pennsylvania, 15904

If you submitted a bid prior to this Addendum being issued, your bid has been discarded and you must re-submit your bid(s) prior to the bid opening date and time.

ADMINISTRATIVE CHANGES – ALL CONTRACTS

Item 1 - N/A

SPECIFICATION CHANGES – ALL CONTRACTS

Item 1 - See attached Addendum 12 PDF.

DRAWING CHANGES – ALL CONTRACTS

Item 1 - N/A

DEPARTMENT OF GENERAL SERVICES
BUREAU PRE-CONSTRUCTION
1800 HERR STREET
HARRISBURG, PENNSYLVANIA

ADDENDUM NO. 12

on

PROJECT NO. DGS C-0948-0090 PHASE 003

PROJECT TITLE - Capitol Complex Central Plant - Building Renovations, Chiller System Replacement and Electrical System Upgrades

PROFESSIONAL:

H.F. Lenz Co.

1407 Scalp Avenue

Johnstown, Pennsylvania 15904

If you submitted a bid prior to this Addendum being issued, your bid has been discarded and you must re-submit your bid(s) prior to the bid opening date and time.

ADMINISTRATIVE CHANGES – ALL CONTRACTS

Item 1 - **N/A**

GENERAL CHANGES – ALL CONTRACTS

Item 1 - **N/A**

DRAWING CHANGES – ALL CONTRACTS

Item 1 - **N/A**

SPECIFICATION CHANGES – CONTRACT NO. DGS C-0948-0090 PHASE 3.1

Item 1 - **N/A**

DRAWING CHANGES – CONTRACT NO. DGS C-0948-0090 PHASE 3.1

Item 1 - **N/A**

SPECIFICATION CHANGES – CONTRACT NO. DGS C-0948-0090 PHASE 3.2

Item 1 - **N/A**

DRAWING CHANGES – CONTRACT NO. DGS C-0948-0090 PHASE 3.2

Item 1 - **N/A**

SPECIFICATION CHANGES – CONTRACT NO. DGS C-0948-0090 PHASE 3.4

Item 1 - Section 261323, Article 2.4, Paragraph B, Change sub-paragraph 1 to read:

" Deadfront, metal-enclosed, fixed-mount, fusible interrupter switchgear assembly of vertical sections.

Item 2 - Section 261323, Article 2.5, Paragraph A, Change sub-paragraph 1 to read:

" Deadfront, metal-clad, drawout, switchgear assembly of individual vertical sections, each with vacuum circuit breakers and auxiliaries, bolted to a rigid metal-clad switchgear assembly. Metal side sheets shall provide grounded barriers between adjacent structures and solid removal metal barriers shall isolate the major sections of each circuit. Additional vertical sections must be provided to house accessories related to the switchboard functions.

DRAWING CHANGES – CONTRACT NO. DGS C-0948-0090 PHASE 3.4

Item 1 - **N/A**