

DATE: August 7, 2025

DEPARTMENT OF GENERAL SERVICES
BUREAU OF CAPITAL PROJECT DESIGN MANAGEMENT
1800 HERR STREET
HARRISBURG, PENNSYLVANIA

ADDENDUM NO. 5

on

PROJECT NO. DGS C-0374-0006 PHASE 002

PROJECT TITLE - SCI Somerset - Medium Voltage Upgrades

PROFESSIONAL:

CJL Engineering

232 Horner Street

Johnstown, Pennsylvania, 15902

If you submitted a bid prior to this Addendum being issued, your bid has been discarded and you must re-submit your bid(s) prior to the bid opening date and time.

SPECIFICATION CHANGES – ALL CONTRACTS

Item 1 - The use of dead break connectors is acceptable.

Item 2 - The specifications indicate a "proposed" sequence of construction and shutdown duration.

Item 3 - The existing dead break connectors in the manholes may or may not be usable due to the sequencing of the project.